



**AAMA/WDMA/CSA 101/I.S.2/A440-08
TEST REPORT**

Rendered to:

INTERWINDOWS USA//ETEM

SERIES/MODEL: E 2400

PRODUCT TYPE: Aluminum Tilt and Turn Window

| Title | Summary of Results |
|--|--|
| Primary Product Designator | Class AW-PG90 1530 x 2515 (60 x 99)-DAW |
| Design Pressure | ±4320 Pa (±90.28 psf) |
| Operating Force (in motion) | 49 N (11 lbf) |
| Air Infiltration | 0.2 L/s/m ² (0.04 cfm/ft ²) |
| Water Penetration Resistance Test Pressure | 580 Pa (12.12 psf) |
| Uniform Load Structural Test Pressure | ±6480 Pa (±135.42 psf) |
| Forced Entry Resistance | Grade 10 |

Test Completion Date: 12/29/08

Reference must be made to Report No. 86264.01-109-44, dated 03/10/09 for complete test specimen description and data.

130 Derry Court
York, PA 17406-8405
phone: 717-764-7700
fax: 717-764-4129
www.archtest.com