



**AAMA/WDMA/CSA 101/I.S.2/A440-08
TEST REPORT**

Rendered to:

INTERWINDOWS USA//ETEM

SERIES/MODEL: 2410

PRODUCT TYPE: Aluminum Fixed Window

Title	Summary of Results
Primary Product Designator	Class AW-PG80 1524 x 2515 (60 x 99)-FW
Design Pressure	±3840 Pa (±80.25 psf)
Air Infiltration	<0.1 L/s/m ² (<0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	580 Pa (12.12 psf)
Uniform Load Structural Test Pressure	±5760 Pa (±120.38 psf)
Forced Entry Resistance	Grade 40

Test Completion Date: 11/13/08

Reference must be made to Report No. 86257.01-109-44, dated 03/11/09 for complete test specimen description and data.

130 Derry Court
York, PA 17406-8405
phone: 717-764-7700
fax: 717-764-4129
www.archtest.com